



Connect the temperature sensors from the Molly304 with 2 conductor 22awg wire. The sensor has a two position terminal block on the circuit board.

If extending sensor leads utilize sensor extension cable  
 Part Number: WIR-I-22-250 or Equivalent  
 (see Notes)

**Notes:**

Sensor wiring can be extended using a variety of methods. Please refer to <http://support.TemperatureGuard.com> for alternate wiring methods such as utilizing existing twisted pair/CAT5 cabling.

Temperature Sensors and Door Sensors are not polarized.

DRAWN BY  <b>TEMPERATURE GUARD MICROTECHNOLOGIES, INC.</b>	TITLE  <b>MOLLY304 WIRING DIAGRAM</b>	PAGE  1 OF 1
	DESCRIPTION  <b>Connecting a Molly304 netGuard</b>	DATE  4/15/2007